

Reliability of a Radial Distribution System by developing network reconfiguration in accordance with failure mode

Abdullah Al Masud¹, Mst. Sharmin Kader², Han Xiao Qing³

^{1,2}Post graduate student, department of Electrical & Electronics Engineering, Taiyuan University of Technology, Shanxi, China.

³Dean & Professor, Department Electrical & Electronics Engineering, Taiyuan University of Technology, Shanxi, China.

Abstract— Reliability investigation assumes a critical job in structuring and arranging of radial distribution systems that work for insignificant interference of client end electric loads. Power distribution systems are known as the constituent piece of power systems with the most noteworthy convergence of failure occasions. Despite the fact that the deficiencies in distribution systems have a nearby impact when contrasted with the age and transmission ides, significant possibility acceleration occasions are as a rule all the more every now and again announced from this segment. Mix of new innovations, mechanization and expanded entrance of disseminated age is required to make improving and in any event, supporting high reliability measures a mind-boggling task. Therefore, this paper is planned to glance in to one factor of feeder disappointment and reconfigure in understanding.

Keywords— Reliability, Radial Distribution system, Network reconfiguration, Failure Nodes.

I. INTRODUCTION

Power systems are one of the most perplexing frameworks discovered worldwide and they are required to work with high caliber and reliability. The principal reason for power systems is to give a monetary and solid channel for electrical vitality to move from purposes of age to client areas. The monetary and reliability requirements can be commonly focused, making arranging and activity of power systems an intricate issue [1].




Fig.1: Distribution of component reliability over primary and secondary sides

The distribution system reliability assessment considers the capacity of the distribution system to move vitality from mass inventory focuses, for example, run of the mill transmission system end-stations, and from neighborhood age focuses, to client loads. In the beginning periods of broad power system development, moderately less consideration was given to distribution systems on account of their lower capital escalation when contrasted with a long separation transmission systems. Likewise, the blackouts in distribution systems are relied upon to have a confined impact [1]. Notwithstanding, examination of handy utility disappointment registers and shortcoming measurements uncovers that distribution arranges as a sub-area of the power systems contribute the most to client interferences and disappointment occasions [2-4]. With headways in innovations both coordinated in power systems and utilized in connection to it, a danger of increment in disappointment frequencies in power distribution segments is normal [34]. Presentation and augmentations in system computerization, wide development in power request entanglements because of dispersed age and so forth are contributing elements to this hazard [5]. These headways are required to improve the presentation of power system. In any case, remembering that the included segments are rarely great, the option of a segment which can experience disappointment in this manner

presents an extra danger of disappointment in the system. (Figure 1-2)




Fig.2: System and Component fault classification

Observing failure and analyzing the impact

The talk here spotlights on the station and feeder engineering at the usage end of power matrix. The consistent tasks and disappointment effects of circuit breakers and individual insurance systems are considered. Here, the term 'disappointment' can show either an inaccessible status of a segment while activity is required or an undesirable mal-activity when no such activity is required [26]. The various potential methods of disappointment in such a situation are dynamic disappointment occasions, uninvolved disappointment occasions, stuck-state of breakers and covering disappointment occasions [27].

Active Failure

Dynamic disappointment occasions are the most widely recognized mode among power system disappointments [27]. Consider a short out deficiency in a conductor part for instance. In such a case, the defective conductor is disengaged from the remainder of the system by the opening activity of an electrical switch liable for the specific insurance zone. In this model, the main broken segment is the conductor which encountered a short out and the

insurance system and the breaker hand-off worked subsequently is intended for.

Passive Failure

While characterizing the term disappointment, one of the potential conditions in thought is an undesirable mal-activity in system where no dynamic disappointment is available to start it [26]. Uninvolved disappointment occasions are such situations where an undesired open circuit happens with no other issue in the system to trigger it. Consequently, inactive disappointments are not described by flaw flows that are detected by assurance systems. The purposes behind aloof disappointment occasions can be physical or material disappointment, bogus hand-off activating from security systems, absence of circumstance mindfulness from human administrator and so on. Consequently, the guilty party segment on account of an aloof disappointment occasion ought to be comprehended from the reason for the occasion, to evade wrong estimations in segment disappointment insights. Despite the fact that there is plausibility of detached activities, for example, dis-connector disappointments rising to cut off because of contact with encompassing parts or ground [28], a regular inactive disappointment occasion just disengages the clients legitimately provided idea the line that got opened.

Covering Failure Modes

This disappointment mode is in the key focal point of the dialog here. Covering disappointments are where a system is encountering halfway or complete disappointment or experiencing a separate fix process and an extra disappointment happen covering with this condition. Such covering disappointments happen in power system activity either because of arbitrary reasons or because of the expanded disappointment hazard forced by the main disappointment or fix circumstance. Presentation of more automation in power system activity and control builds the normal recurrence of these sorts of disappointments. Short disengagements and disappointments covering in orders higher than two segment deficiencies are disregarded, as by and large proposed for these counts [13]. The accompanying area further grows the particular cases considered and the separate causes and highlights of covering disappointment occasions.

Prior Observation

Before the improvement thinking about eagerness to contribute, a base conceivable link length that could associate the hubs in the reference model was assessed, disregarding far as possible and effect of operational blackout cost of links.

The outcome henceforth is a for all intents and purposes non-practical and less dependable development. In any case, it communicates the conceivable least length of link that the

system can have. The comparing absolute link length is roughly 25 km. note that the current system has an absolute link length of round 60 km.

Substation	Total Number of Feeders	Station level SAIFI (failure/customer*year)	Average feeder length per station (km)	Net failure rate for feeder component (failure/yr)	Number of separated busbars	Busbar	Number of feeders per busbars	Busbar level SAIFI (failure/customer*year)
1	43	0.134	1.467	0.02641	4	1	10	0.031163
						2	9	0.028047
						3	12	0.037395
						4	12	0.033950
2	44	0.602	2.047	0.03685	8	5	7	0.095773
						6	7	0.095773
						7	6	0.082091
						8	6	0.082091
						9	3	0.041045
						10	3	0.041045
						11	6	0.082091
						12	6	0.082091
3	48	0.103	1.303	0.02345	8	13	8	0.017167
						14	8	0.017167
						15	4	0.008583
						16	4	0.008583
						17	4	0.008583
						18	4	0.008583
						19	8	0.017167
						20	8	0.017167
4	15	0.271	3.169	0.05704	2	23	7	0.126467
						24	8	0.144566
5	12	0.192	6.062	0.10912	2	25	6	0.096000
						26	6	0.096000
6	18	456	2.156	0.03881	2	27	9	0.228000
						28	9	0.228000
7	30	0.418	4.057	0.07303	2	31	15	0.209000
						32	15	0.209000
8	26	0.451	3.796	0.06833	2	33	13	0.225500
						34	13	0.225500
9	14	0.158	5.513	0.09923	2	35	8	0.090286
						36	6	0.067714

The eagerness to contribute is considered inside the range 10 to half. In useful cases, there consistently exist restrictions in the quantity of ventures and changes that can be made on a working network. Thus, recommending a few changes by constraining the improvement to do so isn't extremely noteworthy. Here the scope of ability to contribute for >50% isn't displayed; however, the program can have any range. In any case, if extension of a current system should be done to another territory, or when another system is being developed without any preparation, such investigation can be utilized if

the hubs of optional station areas are chosen. On the off chance that the reference contextual analysis model was such a situation where there are no current links and the hubs are unblemished, at that point the streamlining gives the proposal as appeared. The decrease is link length and potential course for flaw heightening the system reliability and execution can be improved. Since the investigation here depends on a current system, this case isn't examined further, as it requests an extremely high speculation.(Table & Chart 1)






Table & Chart 1: Observation Data Evaluation

Network Optimization

This section talks about the target of utilizing reliability effects of different system designs in arranging successful upgrades in distribution systems. The goal is tended to with a cost streamlining approach in which both the venture for reconfiguration in the system and the normal expense of

blackout in the subsequent recommendations are considered. Advancement is directed on a genuine substation model. The accompanying areas present the reference organize, the improvement model, the arrangement of limitations and the important social conditions. The outcomes and examination of the estimations pursue a short time later.




Fig.3: Network suggestion for the reference nodes for constructing from scratch

The reference organize comprises of one essential substation sustaining 52 auxiliary stations through the MV framework. In the current system, there are 24 feeder links having an absolute link of around 60 km, beginning from the essential station and sustaining at least one optional station through the length of the feeder. Certain disentanglements and suspicions are made on the reference model to help the improvement practice and to regard the utility's information security necessities.

The advancement, to utilize the chart hypothesis model, should think about all conceivable link lengths between all conceivable hub associations. From the system, just existing link lengths are known as genuine qualities. Subsequently, a reference model explicit increase factor is determined as a normal, contrasting all current link segment lengths with the two-dimensional separation between particular geographic directions. This duplication figure helps assessing the functional lengths of link required to interface those hubs in the considered system where no genuine connections exist starting at now. This gives a reason for the computation of speculation cost. The duplicate factor acquired from the computation is 1.79. This implies an arrange separation of

one meter in this system requires roughly 1.79 meters of link to associate those directions. (Figure 3-4)

From the revealed pinnacle requests at the auxiliary stations throughout the years, the power request of the sink hubs (the optional station positions) are accepted, which in the considered system fluctuates from 70 to 2400 KVA. In spite of the fact that it is an extraordinary case to expect top requests as hub prerequisites, it enables testing if the power to move limits of the feeder links is continually regarding the potential pinnacles.

Alongside this, from the utility practice, a security edge for the power move limit of the links was determined as demonstrated as follows, preceding settings the requirements of improvement.

Since the system is as of now working in the current express, the stock hub that is the essential substation is accepted equipped for serving the power request of all sink hubs. Innovations, for example, dispersed age and capacity are not considered in the situation as the objective is to enhance setup venture cost that ought to have the option to deal with the system request without different sources than the essential substation.




Fig.4: Existing coordinate network structure of the MV grid

II. CONCLUSION AND FUTURE WORK

Evaluation and effect appraisal of corresponded disappointment occasions and consolidated reliability investigation of essential and optional gear is the main target. The distribution of connected occasions related with the joined effect of electrical switch and insurance systems activity is seen from power utility flaw registers utilizing examination of possibility acceleration. The immediate estimation model proposed for utility application depends on level of possibility heightening, looking at the associated clients in the various feeders with the quantity of clients influenced by different blames in feeder conductors. The plan of distribution systems fluctuates broadly, and thus the demonstrating can be improved from system explicit ways to deal with more speculation strategies, improving comprehension from legitimately accessible disappointment related information.

The estimation practice is trailed by an exact measurement approach where layouts of hypothetical models utilizing RBD were defined to deal with distribution lattice execution insight and information. The investigation subsequently directed on genuine contextual investigation uncovers the separate distribution of concealed bogus stumbling probabilities. The portion of insurance system issues among the all-out number of recorded issues was seen as in the cope of 36% in the considered system. These outcomes are tried and confirmed. The down to earth variety scopes of corresponded disappointment probabilities in systems with different degrees of automation were watched. The capacities and count precision of the connected disappointment likelihood computation apparatus created can be upgraded by

considering system explicit pattern plots. The bend fitting to the ideal gives progressively precise readings of issue heightening probabilities where there is opportunity to get better.

The second goal of the venture report is the utilization of system topologies in figuring system reliability and subsequently the examination of potential upgrades in design of the system. The investigation considering system reliability sway was done to mention significant objective facts. The streamlining incorporated the requirements, for example, load request to client hubs, power move limit of the current system, and so on. The pattern of number of new link establishments required with expanding speculation cost was seen alongside enhancing the absolute link length to be introduced. This examination helps spending plan compelled basic leadership, in organizing exchange venture alternatives. The reconfiguration model was done dependent of existing systems with hubs previously decided. The advancement can be improved to have the ability to recommend ideal situations for the position of optional station transformers if such activities are of huge bit of leeway. It can likewise be reached out to deal with non-radial design. Despite the fact that these are right now uncommon in distribution systems, this capacity would advance the extent of the apparatus to transmission systems arranging, incorporation of disseminated age and so forth. Thus, the expansion and advancement of the works talked about in this venture report have huge worth and application in system reliability improvement.

REFERENCES

- [1] R. Billinton and R. N. Allan, Reliability evaluation of power systems, Second ed. Springer Science & Business Media, 1996.
- [2] H. L. Willis, Power distribution planning reference book. CRC press, 2004.
- [3] G. Dixon and H. Hammersley, "Reliability and its cost on distribution systems," in International Conference on Reliability of Power Supply Systems, IEE Conference Publication, 1977, no. 148, pp. 81-84.
- [4] S. Yin and C. Lu, "Distribution feeder scheduling considering variable load profile and outage costs," IEEE Transactions on Power Systems, vol. 24, no. 2, pp. 652-660, 2009.
- [5] H. Byrd and S. Matthewman, "Exergy and the city: the technology and sociology of power (failure)," Journal of Urban Technology, vol. 21, no. 3, pp. 85-102, 2014.
- [6] Y. He and E. Eriksson, "Simple Distribution Networks, Reliable Power Electricity ", Energiforsk rapport 2015:105, February 2015.
- [7] "Nordel's Guidelines for the Classification of Grid Disturbances," 2009.
- [8] "IEEE Standard Terms for Reporting and Analyzing Outage Occurrences and Outage States of Electrical Transmission Facilities " in "IEEE Std 859- 1987," 1988.
- [9] "Grid Disturbance and Fault Statistics," Nordel, 2007.
- [10] "Nordic Grid Disturbance Statistics 2013," ENTSOE, Regional Group Nordic, 2014.
- [11] H. Hajian-Hoseinabadi, "Impacts of automated control systems on substation reliability," IEEE Transactions on Power Delivery, vol. 26, no. 3, pp. 1681-1691, 2011.
- [12] D. Erwin, T. Kruckewitt, and G. Antonova, "Interrelationship of protection and communication to improve power system reliability," in 68th Annual Conference for Protective Relay Engineers, 2015, pp. 717-726: IEEE.
- [13] K. Jiang and C. Singh, "New Models and Concepts for Power System Reliability Evaluation Including Protection System Failures," IEEE Transactions on Power Systems, vol. 26, no. 4, pp. 1845-1855, 2011.
- [14] X. Yu and C. Singh, "A practical approach for integrated power system vulnerability analysis with protection failures," IEEE Transactions on Power Systems, vol. 19, no. 4, pp. 1811-1820, 2004.
- [15] M. R. Haghighat and M. Karimi, "Risk based multi-objective dynamic expansion planning of sub-transmission network in order to have eco- reliability, environmental friendly network with higher power quality," IET Generation, Transmission & Distribution, vol. 11, no. 1, pp. 261-271, 2017.
- [16] B. Sultana, M. Mustafa, U. Sultana, and A. R. Bhatti, "Review on reliability improvement and power loss reduction in distribution system via network reconfiguration," Renewable and Sustainable Energy Reviews, vol. 66, pp. 297- 310, 2016.
- [17] J. Savier and D. Das, "Impact of network reconfiguration on loss allocation of radial distribution systems," IEEE Transactions on Power Delivery, vol. 22, no. 4, pp. 2473-2480, 2007.
- [18] M. E. Baran and F. F. Wu, "Network reconfiguration in distribution systems for loss reduction and load balancing," IEEE Transactions on Power delivery, vol. 4, no. 2, pp. 1401-1407, 1989.
- [19] V. Parada, J. A. Ferland, M. Arias, and K. Daniels, "Optimization of electrical distribution feeders using simulated annealing," IEEE Transactions on Power Delivery, vol. 19, no. 3, pp. 1135-1141, 2004.
- [20] A. Helseth, "Modelling Reliability of Supply and Infrastructural Dependency in Energy Distribution Systems," 2008.
- [21] P. Zhang, W. Li, and S. Wang, "Reliability-oriented distribution network reconfiguration considering uncertainties of data by interval analysis," International Journal of Electrical Power & Energy Systems, vol. 34, no. 1, pp. 138-144, 2012.
- [22] R. Billinton and R. N. Allan, Reliability evaluation of engineering systems. Springer, 1992.
- [23] K. Kiran Kumar, N. Venkata Ramana, S. Kamakshiah, and P. Nishanth, "State of Art For Network Reconfiguration Methodologies Of Distribution System," Journal of Theoretical & Applied Information Technology, vol. 57, no. 1, 2013.
- [24] L. Tang, F. Yang, and J. Ma, "A survey on distribution system feeder reconfiguration: Objectives and solutions," in Innovative Smart Grid Technologies-Asia (ISGT Asia), 2014 IEEE, 2014, pp. 62-67: IEEE.
- [25] D. P. Montoya and J. M. Ramirez, "A minimal spanning tree algorithm for distribution networks configuration," in Power and Energy Society General Meeting, 2012 IEEE, 2012, pp. 1-7: IEEE.
- [26] J. Meeuwssen and W. Kling, "Effects of preventive maintenance on circuit breakers and protection systems upon substation reliability," Electric power systems research, vol. 40, no. 3, pp. 181-188, 1997.
- [27] D. Nack, "Reliability of substation configurations," Iowa State University, vol. 7, 2005.
- [28] S. Larsson and A. Danell, "The black-out in southern Sweden and eastern Denmark, September 23, 2003," in Power Systems Conference and Exposition, 2006. PSCE'06. 2006 IEEE PES, 2006, pp. 309-313: IEEE.
- [29] B. O. Agili, M. M. A. AL-Ziz, and H. K. Yossif, "Prevention of sympathetic tripping phenomena on power system by fault level management," in 2008 IEEE/PES Transmission and Distribution Conference and Exposition, 2008, pp. 1-14.
- [30] K. I. Jennett, C. D. Booth, F. Coffele, and A. J. Roscoe, "Investigation of the sympathetic tripping problem in power systems with large penetrations of distributed generation," IET Generation, Transmission & Distribution, vol. 9, no. 4, pp. 379-385, 2014.

- [31] M. Lavorato, J. F. Franco, M. J. Rider, and R. Romero, "Imposing radiality constraints in distribution system optimization problems," *IEEE Transactions on Power Systems*, vol. 27, no. 1, pp. 172-180, 2012.
- [32] L. L. Grigsby, *Electric power generation, transmission, and distribution*. CRC press, 2016.
- [33] P. Hilber, "Maintenance optimization for power distribution systems," KTH, 2008.
- [34] S. Babu, P. Hilber, and J. H. Jürgensen, "On the status of reliability studies involving primary and secondary equipment applied to power system," in *International Conference on Probabilistic Methods Applied to Power Systems (PMAPS)*, pp. 1-6, IEEE, 2014.
- [35] S. Babu, E. Shayesteh, and P. Hilber, "Analysing correlated events in power system using fault statistics," in *International Conference on Probabilistic Methods Applied to Power Systems (PMAPS)*, pp. 1-6, IEEE, 2016.
- [36] S. Babu, P. Hilber, E. Shayesteh, and L. E. Enarsson, "Reliability Evaluation of Distribution Structures Considering the Presence of False Trips," in *IEEE transactions on smart grid*, pp. 1-8, 2016.
- [37] S. Babu, and P. Hilber, "Reliability and Sensitivity Analysis of Substation and Feeder Design Considering Correlated Failures," in *CIGRÉ SC B3 (Substations) Colloquium*, pp. 1-9, 2017.
- [38] S. Babu, A. Rasouli, E. Shayesteh, and P. Hilber, "System Reliability Centred Distribution Network Reconfiguration Considering Investment and Outage Cost," Submitted to *IEEE transactions on power systems*
- [39] S. Babu, "Reliability Evaluation of Distribution Systmes Considering Failure Modes and Network Configuration", Doctoral thesis 20171024, Department of Electromagnetic Engineering, School of Electrical Engineering, KTH, Stockholm Sweden.